

Water Testing Results - Armadillo Technical Institute

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Big Building - Kitchen Sink		3/5/2020	0.913
Big Building - Small Bathroom		3/5/2020	2.56
Big Building - Chalk Bathroom		3/5/2020	0.82
Big Building - Drinking Fountain		3/5/2020	0.974
Thing 1 - Utility Sink		3/5/2020	2.92
Thing 1 - Bathroom		3/5/2020	1.57
Math - Drinking Fountain		3/5/2020	0.311
Math - Front Bathroom		3/5/2020	1.86
Math - Back Bathroom		3/5/2020	3.18
LA - Drinking Fountain		3/5/2020	0.297
LA - Front Bathroom		3/5/2020	1.63
LA - Back Bathroom		3/5/2020	2.61

ND = Non Detect - Lead level is below the set detection limits of X ppb

Lab Sheets report lead content in ug/L - 1 ug/L = 1 part per billion (ppb)